



City of Sedro-Woolley Fire Department

Dean Klinger, Chief
325 Metcalf Street
Sedro-Woolley, WA 98284

(360) 855-2252 • Fax (360) 855-0196

The Sedro-Woolley Fire Department is currently accepting written quotes on 600 ft each of the following.

- ▶ New double jacketed 5 inch with storz couplings. Hose will be yellow in color and must meet or exceed NFPA1961 specifications. Hose will be 100 foot in length.
- ▶ New double jacketed 2- ½ inch hose with standard coupling. Hose will be yellow in color and must meet or exceed NFPA 1961 specifications. Hose will be 50 foot in length.
- ▶ New double jacketed 1-3/4 inch hose with standard coupling. Hose will be red in color and must meet or exceed NFPA 1961 specifications. Hose will be 50 foot in length.

All quotes must be received no later than June 1st at 2 PM. The Fire Department will accept faxed quotes.

All quotes will include sales tax and delivery charges to Sedro-Woolley Fire Department.

Any questions please contact me at 360-855-3207

Thank you

Dean Klinger, Chief
Sedro-Woolley Fire Department