

**REICHHARDT & EBE ENGINEERING, INC.**  
**CONSULTING ENGINEERS**

---

---

**FAX TRANSMITTAL**

---

---

TO: All Bidders	FROM: James L. Hobbs, Jr., P.E.
COMPANY:	DATE: 5/7/08
FAX NUMBER:	TOTAL NO. OF PAGES INCLUDING COVER: 2
PHONE NUMBER:	FAX NUMBER: (360) 855-1164
RE: Metcalf St. Sanitary Sewer Project	PHONE NUMBER: (360) 855-1713

---

---

URGENT     FOR REVIEW     PLEASE COMMENT     PLEASE REPLY     PLEASE APPROVE

---

---

ADDENDUM NO. 3

**Metcalf Street Sanitary Sewer Improvement Project**  
City of Sedro-Woolley


**To the attention of all bidders for the above project:**

Please find the enclosed Addendum No. 3 for the above referenced project.

The enclosed ADDENDUM is to be considered as much a part of the Contract Documents as if it were included in the body of the plans and specifications, and will be incorporated in and made a part of the contract when awarded and when formally executed.

The Bidder shall acknowledge in writing, on the bid form, this addendum in order to have the bid considered.

Sincerely,



James L. Hobbs, Jr., P.E.

REICHHARDT & EBE ENGINEERING, INC.

**ADDENDUM NO. 3**

To the Contract Provisions for  
City of Sedro-Woolley, Washington

**Metcalf Street Sanitary Sewer Improvements**

**ITEM A**

**SPECIAL PROVISIONS**

**DIVISION 7 DRAINAGE STRUCTURES, STORM SEWERS, SANITARY SEWERS, WATER  
MAINS, AND CONDUITS**


**SECTION 7-10.3(2)A Sewer Flow Bypass Systems**

Section 7-10.3(2)A is supplemented with the following information:

Existing flow into sanitary sewer manhole P4 is approximately 80 gallons per minute (gpm). This flow is approximate only and may increase or decrease depending on rain fall and sewer usage throughout the day. The Contractor shall verify the distance to be pumped and size the pump(s) accordingly.

This ADDENDUM is to be considered as much a part of the Contract Documents as if it were included in the body of the plans and specifications, and will be incorporated in and made a part of the contract when awarded and when formally executed.

The Bidder shall acknowledge in writing, on the bid forms Bid Proposal Signature and Addendum Acknowledgement, this addendum in order to have the bid considered.

  
James L. Hobbs, Jr., P.E.  
Project Manager