



**NOTES:**

1. PROVIDE ROCK CHECK DAMS EVERY 50 FEET OR EVERY 5 FEET OF VERTICAL FALL.
2. DIMENSIONS: 1' MINIMUM DEPTH (D) BY 2' MINIMUM BOTTOM WIDTH.
3. SWALE GRADES SHOULD NOT EXCEED 5%. SIDE SLOPES SHOULD BE 2:1 OR LESS.
4. OUTLET SHALL CONSIST OF RIPRAP DISCHARGING TO STABILIZED OUTLET, SEDIMENT POND OR LEVEL SPREADER.
5. IF DESIGNED AS A PERMANENT DRAINAGE FEATURE, MAY BE USED IN COMBINATION WITH INTERCEPTOR DRAIN. SEE DETAIL 4-24.



PUBLIC WORKS  
DEPARTMENT

TEMPORARY INTERCEPTOR SWALE

DWG. NO.  
4-23