

ATTENTION: All Bidders

ADDENDUM #1

FOR

2018 SANITARY SEWER MANHOLE REPAIR PROJECT

City of Sedro-Woolley Project No. 2018-PW-05

February 13, 2018

The following revisions, additions, and clarifications to the project Proposal, Plans, and Special Provisions are provided for this project:

PROPOSAL FORM:


1. A Force Account item has been added to the proposal. The City has included an amount for this item. *Bidders shall submit bids using the Addendum #1 Proposal Form.*

OTHER INFORMATION:


1. All manholes are concrete. No brick structures.
2. The grouting work will be to seal leaks around the pipe penetrations (i.e. leaky boots, collars). On average the size of the gaps is estimated to be around ¼”.
3. On average expected inflows at gaps is estimated to be up to several gallons per minute in the worst structures.
4. This Addendum will be incorporated in the contract when awarded and when formally executed.

Attachments:

- **Revised Proposal Form**



David Lee, P.E.,
City of Sedro-Woolley
City Engineer



2018 SANITARY SEWER MANHOLE REPAIR PROJECT

2018-PW-05

ADDENDUM #1

PROPOSAL

Proposals due by 2 pm, February 15, 2018

Bids may be submitted in person or by U.S. Mail, facsimile or email to: City of Sedro-Woolley, 325 Metcalf Street, Sedro-Woolley, WA 98284, (360) 855-0771, facsimile 360-855-0733, or by email at jrosario@ci.sedro-woolley.wa.us.

We, the undersigned, hereby agree to bid the following per the "Invitation to Bid – 2018 Sanitary Sewer Manhole Repair Project":

BASE BID: 2018 Sanitary Sewer Manhole Repair Project

ITEM	DESCRIPTION	QUANTITY	UNIT PRICE	TOTAL
1.	Mobilization/Demobilization	1 LS	\$ _____	\$ _____
2.	Repair Manhole	15 EA	\$ _____	\$ _____
3.	Force Account	1 EST	\$ <u>10,000.00</u>	\$ <u>10,000.00</u>
SUBTOTAL			\$ _____	
SALES TAX (8.5%)			\$ _____	
TOTAL			\$ _____	

NOTES:

1. WAC 458-20-170 applies to this project. Washington State Retail Sales Taxes for the various bid item prices will be included as a separate item.
2. All work and materials shall conform to the Project Specifications and as noted below.
3. Contractor shall coordinate with the City for manhole initial cleaning. Contractor responsible for any by-pass pumping if deemed necessary by the Contractor.
4. Contractor is responsible for providing all necessary traffic control labor and devices. Costs associated with traffic control labor and devices shall be included in the repair manhole unit price.

ADDENDUM #1

2018 Sanitary Sewer Manhole Repair Project Proposal Form

2018-PW-05

Page 1 of 2

5. Contractor is responsible for properly disposing of debris from sanitary sewer manholes. Costs associated with removal and disposal shall be included in the repair manhole unit price. Contractor shall prevent debris from getting into the downstream system.
6. Contractor is responsible for compliance with all local, state and federal confined space laws, regulations and rules. Contractor shall provide all necessary safety equipment and materials.
7. Reference the 2018 MH Repair Project Structure Summary list for required repair work at specific structures. The unit price per each for Repair Manhole shall include all labor, equipment and materials necessary to complete the indicated repairs including necessary traffic control labor and devices, and by-pass pumping.

BIDDER COMPANY NAME: _____

ADDRESS: _____

CONTACT: _____

UBI #: _____

TELEPHONE: _____

EMAIL: _____

SIGNATURE: _____

ADDENDUMS ACKNOWLEDGED: ____