



NOTES:

1. MAXIMUM WIDTH OF TRENCH AT TOP OF PIPE:
  - \* 30" FOR PIPE UP TO AND INCLUDING 15" NOMINAL DIAMETER.
  - \* FOR PIPES LARGER THAN 15" THEN TRENCH WIDTH SHALL BE  $= (1.5 \times I.D.) + 18"$
2. ALL DENSITIES TO BE DETERMINED BY A MODIFIED PROCTOR. (ASTM D1557)



PUBLIC WORKS  
DEPARTMENT

STORM SEWER TRENCH DETAIL

DWG. NO.  
4-8