



- NOTES:**
1. BAFFLES AND WEIR TO BE PRECAST CONCRETE
 2. CONTRACTOR TO:
 - A. SET & GROUT BAFFLES & WEIR WALLS.
 - B. FILL WITH CLEAN WATER AFTER BACKFILLING IS COMPLETE AND PRIOR TO "START-UP" OF SYSTEM.

DIMENSION NOTE:
 THE CONTRACTOR OR PROJECT ENGINEER SHALL PROVIDE A DESIGN TO THE CITY ENGINEER. ALL GREASE INTERCEPTOR DIMENSIONS AND LOADING SHALL BE VERIFIED WITH THE MANUFACTURER PRIOR TO THE INTERCEPTORS SELECTION. THE PROVIDED DIMENSIONS ARE ESTIMATIONS.



PUBLIC WORKS
DEPARTMENT

GREASE INTERCEPTOR
SAMPLE DETAIL 1

DWG. NO.
5-9A