

City of Sedro-Woolley

ADDENDUM NO. 1

TO THE PLANS, SPECIFICATIONS, PROPOSAL AND AGREEMENT FOR THE CITY OF SEDRO-WOOLLEY

2020 WINNIE HOUSER PARK RESTROOM COMMERCIAL DOOR INSTALLATION & UNIT PRICED (ON-CALL) MAINTENANCE

Addendum Issued: June 19th, 2020
Date of Bid Opening: June 30th, 2020

TO ALL BIDDERS:

You are hereby notified of the following changes, revisions, deletions, additions, corrections and/or clarifications to the plans, specifications, and agreement documents for the **2020 WINNIE HOUSER PARK RESTROOM COMMERCIAL DOOR INSTALLATION & UNIT PRICED (ON-CALL) MAINTENANCE**. This addendum is made part of these agreement documents as though it was originally included in the Agreement. The Contractor shall acknowledge receipt and understanding of the Addenda on the BID PROPOSAL – ADDENDUM NO. 1 FORM.

ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE INVITATION FOR BID AND BID PROPOSAL FORM

ITEM NO. 1: DOOR SPECIFICATIONS

1. Single exterior grade commercial steel door, 48 16 Gauge, Pre Primed, welded steel frame, polystyrene or honeycomb core, Right Hand In-swing, machined for cylindrical deadbolt hardware. Rough opening 40 ½" x 86 ¼", stainless hinges, stainless kick plate, stainless handle & pull plate, no closing hardware needed.
2. Single exterior grade commercial steel door, 48 16 Gauge, Pre Primed, welded steel frame, polystyrene or honeycomb core, Left Hand In-swing, machined for cylindrical deadbolt hardware. Rough opening 40 ½" x 86 ¼", stainless hinges, stainless kick plate, stainless handle & pull plate, no closing hardware needed.
3. Single exterior grade commercial steel door, 48 16 Gauge, Pre primed, welded steel frame, polystyrene or honeycomb core, Left Hand Out-swing,

machined for cylindrical deadbolt hardware. Rough opening 40 ½ x 86 ¼", stainless hinges, stainless kick plate, stainless handle & pull plate, no closing hardware needed.

ITEM NO. 2: BID PROPOSAL FORM

Replace BID PROPOSAL form with the following:

BID PROPOSAL – ADDENDUM 1